

NOTES:

- -PLATE PER CSA G40.21 50W, MIN.FY=60 KSI, ULTIMATE STRENGTH
- -TUBE PER ASTM A500 GR C, FY=60KSI, FU=70KSI
- 2-ANY CHANGE OF MATERIAL IS SUBJECT TO GOLIATHTECH APPROVAL
- 3-WELD PERFORMED IN ACCORDANCE WITH CSA STANDARD W47.1 AND GOLIATHTECH WELDING PROCEDURES. WELDERS ARE ALSO CERTIFIED TO THE AWS STANDARD.
- 4-HOT-DIP GALVANIZED, PARTS PER ASTM A123.

| 3 | | |
|-----|-----------------|------------|
| 2 | | |
| 1 | INITIAL RELEASE | 2023-05-19 |
| REV | MODIFICATION | DATE |

REVISION

GOLIATHITECH

TITLE: Screw Pile of 2 3/8 (0.154 wall) with a 09" Helix

| EAL: | DWG. NO : |
|------|-------------|
| | GTPI23809 |
| | DRAWN BY: |
| | R.E |
| | DESIGN BY: |
| | GOLIATHTECH |
| | CHECK BY: |
| | СРОС |
| | APP BY: |
| | CPOC |
| | OTHER NO: |
| | - |

| FORMAT : A | REV.: | DATE: | PAGE: | | | |
|---|-------|------------|-------|--|--|--|
| SCALE: NTS | 1 | 2023-05-19 | 1 DE | | | |
| THIS DOCLIMENT CONTAINS PROPRIETARY INFORMATION AND MAY NOT BE REPRODUCED OR COPIED | | | | | | |

WITHOUT THE EXPRESS WRITTEN PERMISSION OF A DULY AUTHORIZED REPRESENTATIVE OF GOLIATHTECH INC.

| ı | | Dimension (inches) | Description | WILCHANICAL ASD LOAD CAPACITY | | | | | | | |
|---|-----|-----------------------|-------------|-------------------------------|-----------------------|--------------|--------------|---------|---------|----------------------|---------------------|
| | NO. | | | d Shaft Lifts | Compression (kips) | | Tension | Lateral | Bending | Max Soil Capacity | |
| | | | | Juppaced Straft, Lifes | 0 Coupler | 1 Coupler | 2 Coupler | (kips) | (kips) | Moment (kips.ft) | Comp/Ten* (kips) |
| ı | Α | 84 | | 0 | 33.4 | 33.4 | 33.4 | 15.57 | 8.20 | 1.93 | 15.75 |
| l | В | 9 | | 5 | 12.4 | 6.7 | 4.0 | | | | |
| ı | С | 4 1/4 | | 10 | 5.5 | 4.0 | 2.8 | | | | |
| I | D | PITCH 3 | | 15 | 2.8 | 2.4 | 1.9 | | | | |
| ١ | Е | 3/8 | | 20 | 1.8 | 1.6 | 1.3 | | | | |
| ı | E | 1 | | Note: | | | | | | | |

1 1/2

2 3/8

9/16

Weld

1/4

Н

- 1. Soil capacity (P4) must be determined per Section 4.1.5 of this report.
- 2. Maximum ultimate soil capacity is determined from Pult = Kt x T based on the corresponding maximum installation torque rating for the specific pile model. Allowable soil capacity is determined from Pa = Pult /2.0 based on the corresponding maximum installation torque rating for the specific pile model. See Section 4.1.5 for additional information.

MECHANICAL ASD LOAD CAPACITY

- 3. Mechanical torsion rating is the maximum torsional resistance of the steel shaft.
- 4. Maximum Torque Per Soil Tests is the maximum torque achieved during field axial verification testing that was conducted to verify the pile axial capacity related to pile-soil
- 5. Maximum Installation Torque rating is the lower of the "mechanical torsion rating" and the "maximum torque per soil tests".
- 6. The allowable soil capacity under the IRC must be determined in accordance with Equation 3 of Section 4.1.5 of this report, when applicable.
- *7. Min required installation depth for tension is 12D where D is the diameter of the uppermost helix.
- 8. Max Soil Capacities based on the tube torsional capacity.