

NOTES:

- 1-MATERIALS:
- HELIX PLATE PER CSA G40.21 50W, MIN.FY=60 KSI, ULTIMATE STRENGTH 70 KSI
- -TUBE PER ASTM A500 GR C, FY=60KSI, FU=70KSI

1

2-ANY CHANGE OF MATERIAL IS SUBJECT TO GOLIATHTECH APPROVAL 3-WELD PERFORMED IN ACCORDANCE WITH CSA STANDARD W47.1 AND GOLIATHTECH WELDING PROCEDURES. WELDERS ARE ALSO CERTIFIED TO THE AWS STANDARD.

В

| 3 | | |
|-----|-----------------|------------|
| 2 | | |
| 1 | INITIAL RELEASE | 2023-07-27 |
| REV | MODIFICATION | DATE |

GOLIAŢHTECH

GOLIATHTECH VENTURA LINE

TITLE: 10 Foot Screw Pile of 2 3/8 (0.154 wall) with a 11" Helix

SEAL:

DWG. NO:
VGTPI23811-10FT

DRAWN BY:
R.E

DESIGN BY:
GOLIATHTECH
CHECK BY:
CPOC
APP BY:
CPOC
OTHER NO:

| FORMAT : A | REV.: | DATE : | PAGE: | |
|------------|-------|------------|-------|--|
| SCALE: NTS | 1 | 2023-07-27 | 1 DE | |

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION AND MAY NOT BE REPRODUCED OR COPIED WITHOUT THE EXPRESS WRITTEN PERMISSION OF A DULY AUTHORIZED REPRESENTATIVE OF GOLIATHTECH INC.

| ı | | Dimension (inches) | Description | MECHANICAL ASD LOAD CAPACITY | | | | | | | |
|---|-----|-----------------------|-------------|---|-----------------------|--------------|--------------|---------|---------|-----------|----------------------|
| | NO. | | | Unbraced Staff, Luften | Compression (kips) | | | Tension | Lateral | Bending | Max Soil Capacity |
| l | | | | | 0 Coupler | 1 Coupler | 2 Coupler | (kips) | (kips) | (kips.ft) | Comp/Ten * (kips) |
| l | Α | 120 | | 0 | 26.3 | 26.3 | 26.3 | 11.74 | 6.40 | 1.51 | 15.75 |
| l | В | 11 | | 5 | 9.7 | 5.2 | 3.1 | | | | |
| l | С | 4 1/4 | | 10 | 4.3 | 3.1 | 2.2 | | | | |
| l | D | PITCH 3 | | 15 | 2.2 | 1.9 | 1.5 | | | | |
| l | Ε | 3/8 | | 20 | 1.4 | 1.2 | 1.1 | | | | |
| l | F | 1 | | Note: 1. Soil capacity (P4) must be determined per Section 4.1.5 of this report. | | | | | | | |
| l | G | 1 1/2 | | 2. Maximum ultimate soil capacity is determined from Pult = Kt x T based on the corresponding | | | | | | | |

2. Maximum ultimate soil capacity is determined from Pult = Kt x T based on the corresponding maximum installation torque rating for the specific pile model. Allowable soil capacity is determined from Pa = Pult /2.0 based on the corresponding maximum installation torque rating for the specific pile model. See Section 4.1.5 for additional information.

MECHANICAL ACD LOAD CADACITY

- 3. Mechanical torsion rating is the maximum torsional resistance of the steel shaft.
- 4. Maximum Torque Per Soil Tests is the maximum torque achieved during field axial verification testing that was conducted to verify the pile axial capacity related to pile-soil interaction.
- 5. Maximum Installation Torque rating is the lower of the "mechanical torsion rating" and the "maximum torque per soil tests".
- 6. The allowable soil capacity under the IRC must be determined in accordance with Equation 3 of Section 4.1.5 of this report, when applicable.
- *7. Min required installation depth for tension is 12D where D is the diameter of the uppermost helix.
- 8. Max Soil Capacities based on the the tube torsional cpacity.

2 3/8

9/16

1/4

Weld